

June 15, 2023

Gentlemen

Impuestos Nacionales
Present:

Ref. Cabinet Distribution Technical Compliance, LPN GTIC No. 7/2023, for the "ADQUISICIÓN DE EQUIPAMIENTO PARA LA AMPLIACIÓN DEL CENTRO DE PROCESAMIENTO DE DATOS LOS PINOS", CUCE: 23-0035-01-1338004-1-1

To whom it may concern:

KSTAR hereby certifies that the Power Distribution Rack equipment offered by the company NPI S.R.L. for the project of: "ADQUISICIÓN DE EQUIPAMIENTO PARA LA AMPLIACIÓN DEL CENTRO DE PROCESAMIENTO DE DATOS LOS PINOS", meet the following characteristics:

Brand: KSTAR
Model: Power Distribution Rack
Customer Code: H Y-0001

General Characteristics

Main protection 200 amps three-phase.
Nominal voltages 400 V AC (3P + 1N + 1PE)
Frequency 50/60 Hz
It has a monitoring card, event record and it is possible to integrate it into the management system of the SIN "STRUXUREWARE DATA CENTER EXPERT"
Display of voltage, current, power and frequency parameters.

The installation will be carried out by trained and certified personnel by the factory:

Mr. Henry Calle
Mr. Daniel Dorado

Without further ado, I bid farewell with the most distinguished considerations.

Best regards

