

June 15, 2023

Gentlemen

Impuestos Nacionales
Present:

Ref. UPS Technical Compliance, LPN GTIC No. 7/2023, for the " ADQUISICIÓN DE EQUIPAMIENTO PARA LA AMPLIACIÓN DEL CENTRO DE PROCESAMIENTO DE DATOS LOS PINOS", CUCE: 23-0035-01-1338004-1-1

To whom it may concern:

KSTAR hereby certifies that the UPS equipment offered by the company NPI S.R.L. for the project of: " ADQUISICIÓN DE EQUIPAMIENTO PARA LA AMPLIACIÓN DEL CENTRO DE PROCESAMIENTO DE DATOS LOS PINOS ", meet the following characteristics:

Brand: KSTAR
Model: HPM3300E-200
Customer Code: H Y-0001

General Characteristics

The UPS model corresponds to the transformerless online double conversion topology.
The waveform in double conversion online is 100% pure sine wave.
The UPS has bypass, the nominal input and output voltage is 380 / 400 and 415 V AC, the frequency range is between 50 – 60Hz and has standard protection.
The autonomy time is calculated for a charge of 72 kW to 15 minutes with lithium batteries.

The installation will be carried out by trained and certified personnel by the factory:

Mr. Henry Calle
Mr. Daniel Dorado

Without further ado, I bid farewell with the most distinguished considerations.

Best regards

